

STATE OF CALIFORNIA
APPLICATION
FOR
DOMESTIC WATER SUPPLY PERMIT AMENDMENT
FROM

Applicant: SCV Water
(Enter the name of legal owner, person(s) or organization)

Address: 23780 Pine St. Newhall, California 91321

System Name: SCV Water – Valencia Water Division

System Number: CA1910240

TO: Bill Liang, P.E.
Angeles District, Sanitary Engineer
Division of Drinking Water
State Water Resources Control Board
500 North Central Avenue, Suite 500
Glendale, CA 91203



Pursuant and subject to the requirements of the California Health and Safety Code, Division 104, Part 12, Chapter 4 (California Safe Drinking Water Act), Article 7, Section 116550, relating to changes requiring an amended permit, application is hereby made to amend an existing water supply permit to construct and operate (1) Ion Exchange Treatment System for the removal of Perchlorate and (1) one Granular Activated Carbon System for the removal of Volatile Organic Compounds at Well 201. Included in this treatment facility will involve a disinfection system consisting of chloramination with a bulk 12.5% solution of sodium hypochlorite and 40% solution of liquid ammonium sulfate.

FOR OFFICIAL USE

Date Received:

I (We) declare under penalty of perjury that the statements on this application and on the accompanying attachments are correct to my (our) knowledge and that I (we) are acting under authority and direction of the responsible legal entity under whose name this application is made.

Signed By: Keith Abercrombie *Keith Abercrombie*

Title: Chief Operating Officer

Address: 23780 Pine St. Newhall, California 91321

Telephone: 661-388-4934

Dated: 11/23/2022

DDW: 03/2015